ADDENDUM NO. 1

May 10, 2021

TO REQUEST FOR PROPOSALS FOR Conejo Wellfield – Equipment Procurement

NOTICE IS HEREBY GIVEN to bidders that this addendum is issued to make the following changes.

Acknowledge receipt of this Addendum in the space provide in the Price Schedule. Failure to do so may subject the Proposer to disqualify.

1. NOTICE OF REQUEST FOR PROPOSALS

Replace paragraph 1 with:

Independent proposals for the procurement of equipment for the "Conejo Wellfield – Equipment Procurement" for the **1**) granulated activated carbon (GAC) treatment system and **2**) pH adjustment system will be received, separately, by the Camrosa Water District (CWD or District) on Friday, May 21, 2021. The proposals will be reviewed and scored by an evaluation team based on the criteria and requirements defined in the following Request for Proposals (RFP). The cost schedule should be included in a separate emailed PDF and will be opened as the last part of the evaluation and scoring criteria. The District reserves the right to retain all proposals for a period of sixty (60) days after the due date for examination and comparison and to delete any portion of the work from the contract. Submit Proposals to:

2. GENERAL CONDITIONS

Replace paragraph 2 of Section 1.0 General Overview with:

The District is requesting proposals from Vendors to provide a GAC treatment system, pH adjustment system, and appurtenances for their Conejo Wellfield. *The GAC treatment system and pH adjustment system will be procured, independently of each other, by the District and installed by a contractor as part of a GAC Treatment System Integration Project, which will be advertised for bids at a later date.* The following includes several criteria for the District to evaluate, score, and determine a qualified manufacturer/vendor that best meets the District's needs.

Replace 1.3.A with:

1.3.A Once the evaluations for the GAC Treatment System and the pH Adjustment System are completed separately, the successful Vendors shall provide two (2) hard copies and one (1) electronic copy of detailed technical submittals for review by the Camrosa Water District and their consultant engineers. Replace 1.6.A with:

1.6.A. The District's evaluation team shall evaluate the proposals based on the following criteria, *where applicable*:

Replace Price Schedule with: [See Price Schedules Below]



Board of Directors AI E. Fox Division 1 Jeffrey C. Brown Division 2 Timothy H. Hoag Division 3 Eugene F. West Division 4 Terry L. Foreman Division 4 General Manager Tony L. Stafford

PRICE SCHEDULE

Camrosa Water District

GAC TREATMENT SYSTEM

Item No	Description	Quantity	Unit	Total
1	Fixed price for GAC Treatment Facility & Appurtenances per the RFP requirements and specifications	1	LS	\$
2	Fixed price for applicabletaxes	1	LS	\$
3	Fixed price for shipping to job site	1	LS	\$
Total all items	\$			

Total Item Nos 1-3

Acknowledgement of Addendas____

(Amount Written in Words)

VENDOR:	
AUTHORIZED SIGNATURE:	
TITLE	



Board of Directors AI E. Fox Division 1 Jeffrey C. Brown Division 2 Timothy H. Hoag Division 3 Eugene F. West Division 4 Terry L. Foreman Division 5 General Manager Tony L. Stafford

PRICE SCHEDULE

Camrosa Water District

PH ADJUSTMENT TREATMENT FACILITY

Item No	Description	Quantity	Unit	Total
1	CO2 skid & Appurtenances per the RFP requirements and specifications	1	LS	\$
2	Fixed price for applicabletaxes	1	LS	\$
3	Fixed price for shipping to job site	1	LS	\$
Total all items	\$			

Total Item Nos 1-3_____

Acknowledgement of Addendas_____

(Amount Written in Words)

/ENDOR:	
AUTHORIZED SIGNATURE:	
TLE	

3. <u>APPENDIX A, SECTION 43 32 82, GRANULAR ACTIVATED CARBON (GAC) VESSEL</u> <u>SYSTEMS</u>

Add:

1.3.G.4 Supplier fit-up test report certifying that the entire GAC system assembly, including the vessels and valve tree, was integrated in the factory to demonstrate proper alignment of mating components.

Add:

3.7 Shop Fit-Check

The Supplier shall fully integrate the GAC system assembly in the factory prior to transportation to the job sit to ensure that all interconnecting components, including the vessels and valve tree, mate without any misalignment.

APPROVED:

Becca K Bugielski

Becca Bugielski

<u>05/10/2021</u> Date